

## **Calibration Certificate**


## Proteus Industries Inc.

340 Pioneer Way, Mountain View, CA, 94041 ph: 650-964-4163 fax: 650-965-9355 www.proteusind.com

| Customer and Model Information |           |                       |          |                             |                             |  |                    |              |
|--------------------------------|-----------|-----------------------|----------|-----------------------------|-----------------------------|--|--------------------|--------------|
| SO #:                          | 109393    | Model Type:           | PV6004SD | New Calibration or As Found | Certificate Name            |  | Status             | Next Cal Due |
| Customer Name:                 | MEDTRONIC | Serial Number: 246013 |          | New Calibration             | 246013_0222PM-20Feb2015.xls |  | Calibration Passes | 20-Feb-2016  |
| Designed for: Off-the-shelf    |           |                       |          |                             |                             |  |                    |              |
|                                |           |                       |          |                             |                             |  |                    |              |

| Flow Rate Measurement Details and Specification Checks |            |                  |            |                             |   |                                     |   |                          |   |                        |                              |       |                                   |  |
|--|------------|------------------|------------|-----------------------------|---|-------------------------------------|---|--------------------------|---|------------------------|------------------------------|-------|-----------------------------------|--|
|  |            | Calibration Data |            | Process Verification        |   | Within 1/2 of Display Reading Range |   | Fluid (Water) Conditions |   |                        |                              |       |                                   |  |
| Flow Range<br>Percentage                               | Target GPM | Actual GPM       | Actual LPM | Display<br>Reading<br>(GPM) | Required Display<br>Reading with<br>Process Tolerance |                                     | Higher<br>Tolerance for<br>1/2 of Range |                          | within 1/2 of                             | Fluid Temperature<br>C | Viscosity cP -<br>calculated | cSt - | Density<br>(g/cc) -<br>calculated |  |
| 70%(1:1.43)  | 2.80       | 2.80             | 10.59      | 2.8                         | 2.8 (2.883 to 2.715)                                  | Pass                                | 2.841                                   | 2.757                    | Pass                                      | 23.8945                | 0.91                         | 0.92  | 0.9974                            |  |
| 50%(1:2)   | 2.00       | 2.00             | 7.57       | 2                           | 2 (2.041 to 1.957)                                    | Pass                                | 2.020                                   | 1.978                    | Pass                                      | 23.8826                | 0.91                         | 0.92  | 0.9974                            |  |
| 14%(1:7)   | 0.57       | 0.57             | 2.15       | 0.57                        | 0.57 (0.611 to 0.527)                                 | Pass                                | 0.590                                   | 0.548                    | Pass                                      | 23.9169                | 0.91                         | 0.92  | 0.9973                            |  |
|  |            |                  |            |                             |   |                                     |   |                          |   |                        |                              |       |                                   |  |
|  |            |                  |            |                             |   |                                     |   |                          |   |                        |                              |       |                                   |  |
| Passes Process Tolerance No need to readjust display   |            |                  |            |                             |   |                                     |   |                          | <br>· · · · · · · · · · · · · · · · · · · |                        |                              |       |                                   |  |

| Best Fit Straigh | nt Line Equation                  | s for Calibration I |
|------------------|-----------------------------------|---------------------|
| Unit Ou          | tput = (0.2642 *                  | LPM) + 0.0013       |
| Unit Ou          | tput = (0.9999 *                  | GPM) + 0.0013       |
|                  | . ,                               | •                   |
|                  |                                   |                     |
| Flour Dot        | a va Dianlay Or                   | ds.                 |
| Flow Rat         | e vs. Display Or                  |                     |
| Flow Rat         | e vs. Display Or<br>LPM<br>0.2642 | GPM<br>0.9999       |



| Personnel & Dates |                    |  |  |  |  |
|-------------------|--------------------|--|--|--|--|
| Status:           | Calibration Passes |  |  |  |  |
| Calibrated by:    | AVG                |  |  |  |  |
| Date of Cal:      | 20-Feb-2015        |  |  |  |  |
| Approved by:      | SBZ                |  |  |  |  |
|                   | •                  |  |  |  |  |
| Next Cal Date:    | 20-Feb-2016        |  |  |  |  |

|  | Equipment Used             |                             |  |  |  |
|--|----------------------------|-----------------------------|--|--|--|
|  | Flow Rate Calibrator Used: | FS#4 - P3.5a Coriolis Meter |  |  |  |
|  |                            |                             |  |  |  |
|  | Fluid used:                | Water                       |  |  |  |
|  | Plumbing:                  | straight pipe               |  |  |  |
|  |                            |                             |  |  |  |

document form number: 640025, Revision BC document form revision date: 16 June 2014

This Calibration Certificate should not be reproduced except in full, without written approval of Proteus Industries Inc.

Page 1 of 1

view/print date: 1/14/2019 filename: 246013\_0222PM-20Feb2015-Certificate.xls